

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-0047:112 Page 1 of 1

CATEGORY: Door Closers/Holders

LISTEE: Rixson-Firemark, 1902 Airport Rd., Monroe, NC 28110
Contact: Jeff Trull (704) 283-2101 *FAX (704) 292-1788

DESIGN: Models 4PUSH/4PULL and 6PUSH/6PULL SMOK-CHEK VI door closers/holders. Model 6PUSH/6PULL employs a separately listed integral smoke detector module (CSFM Listing No. 0047:111). Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as door closers/holders with or without an integral smoke detector. The integral smoke detector module is approved for use as a releasing device only. When the detector is used, a separately listed compatible control unit must also be used.

XLF: 3550-0257:108

*Rev. 05-21-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**